1748 COUNTY

DIVISION OF PERMITTING AND DEVELOPMENT REVIEW

Frederick County, Maryland

Office Of Life Safety

30 N. Market Street • Frederick, Maryland 21701 Phone (301) 600-3463 • Fax (301) 600-3464 • TTY: Use MD Relay Service

Plan Requirements for the review of Fire Alarm & Detection Systems Permits

The following information shall be provided on/with the plans being submitted:

Contact and Applicant Information

Name of Fire Alarm Contractor Address of Fire Alarm Contractor Telephone & Fax Number, E-Mail Address Name of System Designer, Fax & Telephone Number

Type of Work being performed

New or Modification

Edition & Name of the code

the Fire Alarm System was designed to

Location of Work

Business Name, Address & Use

Quantities

of stories, # of devices

Alarm Control Panel

Manufacturer, model, # of panels

<u>Alarm Devices</u> – both initiating & notifying

Type & model # of all to be used

Calculations

Each battery set; Signal circuit load & voltage drop, and Point to point wiring diagram

Manufacturers Specification Sheets for all equipment

Modifications to existing system

In addition to the above- include the capacity of the system & all modified circuits; the existing load or current draw on each circuit component; capacity available & the additional load of the added circuits.